



PIPE SIZE SHOULD BE BASED ON MANUFACTURER'S RECOMMENDED PIPE DIAMETER TO MAXIMIZE DISCHARGE RATE

**WHERE PRACTICABLE, CONNECTIONS SHOULD BE MADE TO CONNECT TO STORM STRUCTURES.

**CONSIDER A BACK-UP SUMP PUMP SYSTEM. DISCHARGE INTO SEPARATE PIPE.

10. **NEVER CONNECT YOUR SUMP PUMP TO A SANITARY SEWER..

SUMP PUMP DISCHARGE CONNECTION

08/30/01 KRL
 01/22/07 KRL
 07/19/18 MJC

N.T.S.